



USER GUIDE

MAGMATHERM PRIMARY FURNACES

MTP SERIES



-All rights reserved, belongs to TETRA ISI SİSTEMLERİ SAN. TİC. LTD. / ISTANBUL. Any part of this publication cannot be reproduced, copied without permission of Tetra Isi Sistemleri San Tic. LTD / Istanbul.

We would like to thank you, because you have choosen MagmaTherm MTP Series.



CONTENTS

1-DEFINITION.....	3
2-SAFETY.....	3
2.1-PROPER OPERATION.....	3
2.2-OPERATION IN SAFE CONDITIONS.....	5
3-FIRST HEATING.....	6
4-DISPLAY & MENU.....	7
4.1-START & STOP FOR HEATING.....	7
4.2-FOLLOWING, ENTERING & CHANGING PARAMETERS.....	8
4.3-MENU.....	8
4.3.1-MTP SERIES P/PX CONTROL PARAMETERS.....	9
4.3.2-MTP SERIES P/PX CONTROL UNIT MENU.....	9
4.4-BUTTONS.....	10
APPENDIX-1 TECHNICAL SPECIFICATIONS.....	11
APPENDIX-2 CONTROL UNIT FEATURES.....	12

IMPORTANT: BEFORE OPERATING THE FURNACE, OPERATING MANUAL MUST BE READ CAREFULLY.

IMPORTANT: AFTER READING OPERATING MANUAL, DIRECTIONS THAT ARE EXPLAINED IN THE SECTION 8 (FIRST HEATING) SHOULD BE FOLLOWED VERY CAREFULLY, DURING FIRST HEATING/OPERATING PROCESS.



1-DEFINITION

Magmatherm MTP Series are laboratory type heating furnaces. Heating is performed up to 1100°C. Continuous working temperature & adjustable temperature is also up to 1100°C on these furnaces according to selected model.

2-SAFETY

Magmatherm heating furnace may harm operating people or surrounding any other materials, unless this operating manual is applied during operating process.

Thus;

- Periodical maintenance should be applied.
- Cautions against accidents should be main concern of operators.
- All operating directives, warnings and recommendations in this operating manual have to be followed and applied carefully.

Unless operating directives, warnings and recommendations in this operating manual are followed and applied, company TETRA ISI SİSTEMLERİ LTD. ŞTİ. is not dedicated for the accidents that may occur.

2.1-PROPER OPERATION

Magmatherm can reach up to 1100°C. Thus materials that can stand up to 1100°C can be heated in the chamber. The conditions that should be considered during operating or the points which are the reason no to start operational process are as follows,

- Furnace is not started, if there is any living thing in the chamber.
- Any burning, flammable, exploding, poisoning, (Benzene, LPG, Acetylene etc.) material that may harm when it is heated etc. is not stored or put inside the chamber. These types of materials should be kept away from the furnace.



- Outside case of the furnace may be hot. It should be considered. Especially, when the furnace is heated above 1000°C and if it is kept above this temperature 30 minutes or more, you shouldn't touch to outside case/surfaces without using gloves.
- Instant high heat should be considered, when the front door is open.
- Electronic and/or Electrical components may create induction current or magnetic field. It may harm any electronic equipment surrounding the furnace. Especially cardiac pacemaker users should be away from the furnace.
- It should not be operated in closed environments such as in cupboard etc.
- Furnace should not be operated by multi plug in tools. It should be operated by stationary plugs which are mounted on the wall.
- Electricity plug have to be grounded.



Explosive, flammable, burning, poisonous materials, don't heat up.

DANGER



Hot Surface

WARNING



Instant high temperature, when the front door is opened.

DANGER



2.2-OPERATION IN SAFE CONDITIONS

“Contribute in to SAFETY CAUTIONS in the work shop.”

Please obey to safety rules. Please inform responsible person, as soon as you notice any abnormal condition for the furnace.



Please use protective glass or protective gloves, when you are working.

Don't let non-permitted person contact to any electrically alive parts. Possible electrically alive parts should be processed by responsible persons and by experts. Cables should be protected against/away from any heat, oil, oily material, sharp tools and materials. Cables should be kept away from furnace surface. Any cable may kill, if any parts of the cable are broken / damaged or cable touches on to the furnace surface. Any broken cable should be replaced by the new one.



- Danger of life due to electrical shock.

DANGER



- Danger of life due to electrical shock.

DANGER

- To touch in to the electrically alive parts may kill, if cable is broken or damaged. Be aware of the environmental affects: Don't use electrical tools, equipment and machines in wet circumstances. Keep light intensity enough to make easier for the working people. Plug off the machine, before any cleaning, repair and maintenance process.



3-FIRST HEATING

Following conditions should be considered, directions must be applied step by step, and the importance of the first heating process should be kept in mind, when Magmatherm Furnace is operated and heated up for the first time.

3.1-Enough free field, surrounding the furnace should be kept. Recommended distance is minimum 30 cm. This free space will increase the furnace performance because of air circulation. At the same time, any fire or explosion danger which may occur due to any material left around the furnace. Please don't forget, when the furnace reaches to high temperatures, the surface of the furnace reaches to high temperatures too. Any flammable and explosive material which is close to furnace can be a reason for the fire or explosion danger.

3.2-Electricity plug should have proper ground connection and plug should have proper capacity (Cable thickness) according to maximum ampere of the furnace.

3.3-Some gas and fumes due to some chemicals which is used on the electronic parts, in the isolation materials and due to outer furnace surface paint can be harmful if it is breathed directly, during the first heating process. Protective glasses and breathing masks should be definitely used, during first heating and very good air circulation in the working room should be kept.

3.4- During the first heating up process, furnace should be heated up according to following temperature-time table

Heating up to 1100°C (or maximum temperature of your model)


Waiting for 1 hour

This procedure can be completed by Magmatherm Programs easily.

Please don't touch furnace without gloves, especially during first heating process, due to hot surfaces.



4-DISPLAY & MENU



Control panel includes 3 buttons (B1, B2, B3), green led and red led (L1, L2) and 3 digit display.

If you see green led (L1) is on, your furnace is ready to start without any problem and the red light (L2) starts, if you start to heat the furnace. When the heating ends, the red led also turn off.

Sound warning is the indication of starting the heating, level changes and finishing the heating procedure.

User interface (Keypad) has two different modes. First one is to understand the status/conditions of the furnace. Point led is turned off during the status mode. Unless you press a button, inner temperature is indicated on the display. If you start to heating and if you press B1 or B2, heating level and heating program can be followed via display.

4.1-START & STOP FOR HEATING

Heating is started, if you press 3-4 seconds "START" (B1) button during the Point Led is turned off.

Sound warning indicates the initiation of heating and working program number is displayed for 3 seconds and main display is followed (That means inner temperature is displayed automatically). At the same time red led (L2) is turned on.



If B1 button is pressed short, actual level of heating procedure is displayed for 2 seconds, these are;

1-First level heating

2-First level waiting

1-Second level heating

2-Second level waiting

It is possible to change the program parameters, even the heating continues. But of course this is valid for the coming steps.

Heating is stopped, if you press "STOP" (B2) button long. (3-4 seconds). Sound warning indicates that you stop the furnace and red led (L2) is turned off.

Note: When energy cut off the working program continues to work, if the energy cut off occurs and supplied again.

4.2-FOLLOWING, ENTERING & CHANGING PARAMETERS

Second mode is to follow and to change the parameters of the heating procedure. Point led at the right bottom of display is turned on.

This mode is initiated when B3 is pressed short. If up or down arrows (B1 & B2) are pressed when the point led is turned on, you follow the each parameters of the program. Parameter which is wanted to be displayed appears and one second later set value appears at the display. B1 and B2 buttons are used to display other parameters.

Parameter can be changed, if B3 button is pressed long and the value starts to blink. B1 and B2 are the buttons to decrease or increase the values. To save the value, B3 is pressed long again while the value is blinking. The value is not saved, if B3 button pressed short and blinking is stopped.

4.3-MENU

P00 mode activates the program which will be displayed and set. Activated menu options depending on the selection of P00 are shown here-below. Parameters of any other program can be changed by changing P00, while the selected program is working.



4.3.1-MTP SERIES P/PX CONTROL PARAMETERS

Parameter No	Parameter Detail	Value Range
P11	SET VALUE TEMPERATURE [C] 1 st PROG 1 st . STEP	50 - 1100
P12	SET VALUE WAITING TIME [Min.] 1 st PROG 1 st . STEP	1 - 999
P15	HEATING RATE [C/min]	5 - 25

Parameters above can be set for MTP P/PX Control Unit. Parameter selection mode appears when the B3 button is pressed (Point led at the bottom right turns on) and working temperature P11, waiting time P12 and heating rate P15 selection can be implemented.

4.3.2-MTP SERIES P/PX CONTROL UNIT MENU

P/PX Control Unit menu is different depending on PO0 selection as follows,

IF PO0 "1"

Parameter No	Parameter Detail	Value Range
PO0	Program Selection	1-2
PO1	Program No (Selected)	
PO2	Step No	1- 4
PO3	Cumulative Working Hour/10	
P11	VALUE TEMPERATURE [C] 1 st PROG 1 st . STEP	50 - 1100
P12	VALUE WAITING TIME [min.] 1 st PROG 1 st . STEP	1 - 999
P13	SET VALUE TEMPERATURE [C] 1 st PROG 2 nd STEP	50 - 1100
P14	VALUE WAITING TIME [min.] 1 st PROG 2 nd STEP	1 - 999
P15	HEATING RATE [C/min]	3 - 20



IF POO "2"

Parameter No	Parameter Detail	Value Range
P00	Program Selection	1-2
P01	Program No (Selected)	
P02	Step No	1- 4
P03	Cumulative Working Hour / 10	
P21	VALUE TEMPERATURE [C] 2 ND PROG 1 ST STEP	50 - 1100
P22	VALUE WAITING TIME [min.] 2 ND PROG 1 ST STEP	1 - 999
P23	SET VALUE TEMPERATURE [C] 2 ND PROG 2 ND STEP	50 - 1100
P24	VALUE WAITING TIME [min.] 2 ND PROG 2 ND STEP	1 - 999
P25	HEATING RATE [C/min]	3 - 20

Any other parameter set can be made, while the selected program is working. It does not affect the behavior of working program.

4.4-BUTTONS

Button	Status Mode		Heating Mode		Parameter Mode		Parameter Set	
	Short Press	Long Press	Short Press	Long Press	Short Press	Long Press	Short Press	Long Press
B1	Not Applicable	Start	Step No	Program No	Parameter Advance	Parameter Advance	Increase the Value	Decrease the Value
B2	Not Applicable	Not Applicable	Not Applicable	Stop	Parameter Back	Parameter Back	Increase the Value	Decrease the Value
B3	Parameter Mode	Not Applicable	Parameter Mode	Not Applicable	Status Mode	Parameter Selection	Out without saving	Saving



APPENDIX-I Technical Specifications

950°C			
	3 Liter		
Inner Chamber Dimensions [mm] WxHxD	130x105x230		
Product Outer Dimensions [mm] WxHxD	335x134x533		
Net Weight [kg]	25		
Power [W]	1500		
Max. Current [A]	7		
Electrical Connection	1 Phase		
Heating Element	Fe-Cr-Al		
Thermocouple Type	K Type		
Heating Element Placement	Embedded into brick walls		
Inner Insulation Material	Insulating Fire Brick		
Front Face Insulation Material	Ceramic Fibre Board		
Door Insulation Material	Ceramic Fibre Board		
Housing Material	Steel Sheet		
Housing Coating	Epoxy powder coating		
Chimney	Standard		
Heating Element Protection	Quartz Tube		
Lockable Door Handle	Sidewards		
Gross Dimensions [mm] WxHxD	420x620x620		
Gross Weight [kg]	35		
1000°C			
	5 Liter	8 Liter	20 Liter
Inner Chamber Dimensions [mm] WxHxD	150x150x225	180x160x260	200x180x300
Product Outer Dimensions [mm] WxHxD	376x559x435	406x569x470	426x589x510
Net Weight [kg]	24	28	34
Power [W]	2.000	2.600	3.400
Max. Current [A]	9,1	11,9	15,5
Electrical Connection	1 Phase	1 Phase	1 Phase
Heating Element	Fe-Cr-Al	Fe-Cr-Al	Fe-Cr-Al
Thermocouple Type	K Type	K Type	K Type
Heating Element Placement	Embedded into brick walls	Embedded into brick walls	Embedded into brick walls
Inner Insulation Material	Insulating Fire Brick	Insulating Fire Brick	Insulating Fire Brick
Front Face Insulation Material	Ceramic Fibre Board	Ceramic Fibre Board	Ceramic Fibre Board
Door Insulation Material	Ceramic Fibre Board	Ceramic Fibre Board	Ceramic Fibre Board
Housing Material	Steel Sheet	Steel Sheet	Steel Sheet
Housing Coating	Epoxy powder coating	Epoxy powder coating	Epoxy powder coating
Chimney	Standard	Standard	Standard
Heating Element Protection	Quartz Tube	Quartz Tube	Quartz Tube
Lockable Door Handle	Sidewards	Sidewards	Sidewards
Gross Dimensions [mm] WxHxD	436x595x619	466x630x629	486x670x649
Gross Weight [kg]	36	41	49
1100°C			
	5 Liter	8 Liter	20 Liter
Inner Chamber Dimensions [mm] WxHxD	150x150x225	180x160x260	200x180x300
Product Outer Dimensions [mm] WxHxD	376x559x435	406x569x470	426x589x510
Net Weight [kg]	24	28	34
Power [W]	2.000	2.600	3.400
Max. Current [A]	9,1	11,9	15,5
Electrical Connection	1 Phase	1 Phase	1 Phase
Heating Element	Fe-Cr-Al	Fe-Cr-Al	Fe-Cr-Al
Thermocouple Type	K Type	K Type	K Type
Heating Element Placement	Embedded into brick walls	Embedded into brick walls	Embedded into brick walls
Inner Insulation Material	Insulating Fire Brick	Insulating Fire Brick	Insulating Fire Brick
Front Face Insulation Material	Ceramic Fibre Board	Ceramic Fibre Board	Ceramic Fibre Board
Door Insulation Material	Ceramic Fibre Board	Ceramic Fibre Board	Ceramic Fibre Board
Housing Material	Steel Sheet	Steel Sheet	Steel Sheet
Housing Coating	Epoxy powder coating	Epoxy powder coating	Epoxy powder coating
Chimney	Standard	Standard	Standard
Heating Element Protection	Quartz Tube	Quartz Tube	Quartz Tube
Lockable Door Handle	Sidewards	Sidewards	Sidewards
Gross Dimensions [mm] WxHxD	436x595x619	466x630x629	486x670x649



APPENDIX-2 Control Unit Features

Choose CU Software	Primary P	EXTENDED Px
Software Based PID Control	YES	YES
Display	7 Segment / 3 Digit	7 Segment / 3 Digit
Heating Program with	Direct	2 steps
Custom Preset Program	1	2
Heating Rate °C/min.	5-25	5-25
Date & Time	NO	NO
Auto Start at Certain Date	NO	NO
Show Remaining Waiting Time	NO	NO
Skip the Waiting Step	NO	NO
Temperature Calibration via Menu ($\pm 10^{\circ}\text{C}$)	NO	NO
Sound Warnings at Step Changes	NO	YES
Sound Warning at the End of the Program	YES	YES
Total Working Hour Counter	NO	NO
Calculator for Average Working Temperature	NO	NO
Instantaneous Energy Consumption Indicator	NO	NO
Target Temperature Display	NO	NO
Step Indicator	NO	YES
Burst Heating Mode	NO	NO
Descriptive Error Indicator	NO	NO
Temperature Control Accuracy***	$\pm 1^{\circ}\text{C}$	$\pm 1^{\circ}\text{C}$
Measurement Accuracy	$\pm 1^{\circ}\text{C}$	$\pm 1^{\circ}\text{C}$
Inner Volume Temperature Homogeneity	$\pm 10^{\circ}\text{C}$	$\pm 10^{\circ}\text{C}$
Control Unit Overheating Sensor	YES	YES
Over Heating Cut Off	YES	YES
PC Connection Kit	OPTIONAL	OPTIONAL
Warranty Period	2 Years	2 Years

2 Years Warranty without Heating Elements, Thermocouple, Consumables and Freight Cost.

Magmatherm Laboratory Furnaces - Tetra Isı Sistemleri Sanayi Ticaret Limited Şirketi

Yunus Emre Mahallesi, Türüt Sokak, No: 14, 34791, Sancaktepe, İstanbul, TURKEY

t: +90 216 484 32 82, f: +90 216 484 32 88, e: magma@magmatherm.com